



Notes

- 1.Pressure rating:150-500kpa. If the pressure exceeds or is likely to exceed 550kpa, an approved pressure limiting device must be installed.
- 2.Temperature rating: 1-75°C. If the water temperature exceeds 55°C, an approved tempering valve must be fitted.
- 3.Flush out all pipes prior to installation.
- 4 Installation should comply with Australia standard AS/NZS3500 or relevant local authority requirements.

Maintenance and Care

- 1.All products should be cleaned with mild detergent or soapy water by using a soft cloth or dampened sponge.
- 2.Dry with a soft cloth after each use and clean regularly.
- 3.Do not use any chemical or abrasive cleaners.