BUILDING PERFORMANCE



CLASS 1

Building Product Information Sheet

| Product name: | | | |
|--|--------------------------|---------------|--|
| Caleffi 502 Series Air Vent 15mm | | | |
| Product line (the product line from which the product is customised): | | | |
| Caleffi | | | |
| Product description and its intended use (measurements, materials, usage): | | | |
| Automatic air vent valve | | | |
| 1/2" male threaded connection | | | |
| Vertical discharge (top bleed) | | | |
| Chrome plated with metallic cap | | | |
| Brass body and cover | | | |
| PP float, brass obturator stem, EPDM O-Rings | | | |
| Product identifier (if applicable): | | | |
| AV502241 | | | |
| Place of manufacture: Legal and trading name of the manufacturer(s): | | | |
| CONFIDENTIAL | | | |
| Legal and trading name of the importer (if applicable): | | | |
| WATERWARE SERVICES LIMITED | | | |
| Address for service: | | | |
| STREET NAME 54 Stonedon Drive | | East Tamaki | |
| CITY, COUNTRY Auckland, New Zealand | | POSTCODE 2013 | |
| Website: | https://www.waterware.co | nz/ | |
| Email address: | info@waterware.co.nz | | |
| Phone No. (if applicable): | 09 273 9191 | | |
| NZBN (if applicable): | 9429038721021 | | |



Relevant Building Code clauses:

B2 Durability — B2.3.1 (c) E3 Internal moisture — E3.3.1 F2 Hazardous building materials — F2.3.1

Statement on how the building product is expected to contribute to compliance:

OEM Specification Sheet: https://www.waterware.co.nz/wp-content/uploads/2021/06/AV5020-5021-5022-OEM-spec.pdf

• options for compliance set out in section 19 of the Act (regulations, acceptable solution, verification method)

• standard or technical document that describes the performance of the building product or the relevant specifications to which the building product was manufactured

• how the building product is intended to be used.

physical properties of the building product

Limitations on the use of the building product:

This product is intended for domestic use only.

Design requirements that would support the use of the building product:

Suitable for residential and commercial applications

Installation requirements:

The unit must be installed by an accredited technician.

Maintenance requirements:

Is the building product/building product line subject to warning or ban under section 26?:

 \Box Yes \boxtimes No

If yes, description of the warning or ban under section 26:

Date:

19/09/2023