

CLASS 1

Building Product Information Sheet

Product name:

Ryemetal 25mm Hose Vacuum Breaker

Product line (the product line from which the product is customised):

Ryemetal

Product description and its intended use (measurements, materials, usage):

25mm hose vacuum breaker
Comprises a single check valve, spring loaded to closed position with atmospheric vacuum breaker vent
Corrosion resistant
Brass body
Suitable for hot or cold water service (up to 80°C at 1400kPa)
Maximum working pressure of 1400kPa
'Breakaway' set screw protects against tampering
Approved to AS 2845.1

Product identifier (if applicable):

BFVB25

Place of manufacture: Aotearoa New Zealand Overseas**Legal and trading name of the manufacturer(s):**

CONFIDENTIAL

Legal and trading name of the importer (if applicable):

WATERWARE SERVICES LIMITED

Address for service:

STREET NAME 54 Stonedon Drive SUBURB East Tamaki

CITY, COUNTRY Auckland, New Zealand POSTCODE 2013

Website:<https://www.waterware.co.nz/>**Email address:**

info@waterware.co.nz

Phone No. (if applicable): 09 273 9191**NZBN** (if applicable):

9429038721021

Relevant Building Code clauses:

B2 Durability — B2.3.1 (c)
E3 Internal moisture — E3.3.1
F2 Hazardous building materials — F2.3.1

Statement on how the building product is expected to contribute to compliance:**Product Details:**

<https://www.waterware.co.nz/products/plumbing/plumbing-valves/backflow/ryemetal-25mm-hose-vacuum-breaker/>

- *options for compliance set out in section 19 of the Act (regulations, acceptable solution, verification method)*
- *standard or technical document that describes the performance of the building product or the relevant specifications to which the building product was manufactured*
- *physical properties of the building product*
- *how the building product is intended to be used.*

Limitations on the use of the building product:

This product is intended for domestic use only.

Design requirements that would support the use of the building product:

Suitable for residential and commercial applications

Installation requirements:

The unit must be installed by an accredited technician.

Maintenance requirements:

Is the building product/building product line subject to warning or ban under section 26?:

Yes No

If yes, description of the warning or ban under section 26:

Date: 19/09/2023